

**GOVERNMENT OF KARNATAKA
PUBLIC WORKS DEPARTMENT**

(http:www.kpwd.gov.in)

e-mail : eeklr@kpwd.gov.in

I.S.O.9001-2008
CERTIFIED DIVISION

Ph.No.08152-222022 Fax No.08152-227443

Office of the Executive Engineer,
Public Works Department Division,
Court Circle, Kolar -563101

No.EEE/PWD/KD/Structural Stable/2021-22 /1643

Date : 04/10/2021


TO:
Principal,
Indian Public School,
Kogilahalli,
Kolar.

Sir,

Sub: Regarding issue of Structural Stable Certificate to Indian
Public School, of Kogilahalli Kolar Taluk.

Ref: 1) Letter of Principal, Indian Public School, Kogilahalli, Kolar,
Dated 27.8.2021.

2) Asst. Executive Engineer, PWD Sub-Division, Kolar, letter
No. 511/2021-22 Dated 21.9.2021.



With reference to the above subject as per letter cited under reference (1)
your Educational Society has sought for issue of Structural Stable Certificate for
the School Building to start your Educational Insitution.

Based on your requestion the Assistant Executive Engineer of Kolar Sub-
Division, has visited the Building on 1.9.2021 and on the investigation made
jointly it is found that the Building is in good condition.

In Ground Floor, First, Second and Third floor class rooms are there and
Toilets and Step rooms are available. It is found that all the Floors are about
3.35 mtrs. are in height.

Further regarding the Structural Stability of the building regarding the
capacity of the building Concrete as per the letter issued by the Karnataka Test
House Private Ltd. on 23.8.2021 NABL Accredited Laboratory as per ISO/IEC
17025 tests are conducted for Non-Destructive tests to assess the
quality/strength of in-situ concrete in RC members using PUNDIT Lab + Portable
Portable Ultrasonic Non-destructive Digital Indicating tester, Ultrasonic Pulse
Velocity tests have been conducted and upon consulting with the Technicians/
Technial concerned of the Sub-Division and on test it is found the building
Structural Stability is in good condition.

The Indian Public School, of Kogilahalli, Kolar, in their requisition letter
have stated that they have constructed the school Indian Public School,
Kogilahalli, Ward No.6, Kolar. As per their say the building is constructed in the
said place.

INDIAN PUBLIC SCHOOL
Ward No.6, Kogilahalli, NH-75

.p.t.o.

Further it is found that the building is constructed as approved by the Town Planning Authority, Kolar Urban Development Authority.

Ultrasonic Pulse Velocity Test.

Conducting Ultrasonic Pulse velocity test for compressive strength of in-situ concrete on columns, roof slabs and beams at Critical points using "PUNDIT 6" (Portable ultrasonic non-destructive Digital Indicating Tester) equipment form M/s. CNS FARNELL U.K. as per the guidelines in Indian Standards (IS : 516(Part 5/Sec 1):2018) Tests have been conducted from M/s.Karnataka Test House Pvt. Ltd. It is found in the test that the building is in good condition.


Recognizance, visual inspection for Building-cracks, distress, dampness etc., tests have been conducted by M/s.Karnataka Test House Pvt. Ltd. It is found in the test that the building is in good condition.

Based on the report made by the Assistant Executive Engineer, Kolar sub-Division, and upon the reports issued by M/s.Karnataka Test House Pvt. Ltd. and based on the certificate issued by the said firm regarding the building stability and on the inspection made by the Technical team of Public Works Department, Kolar Sub-Division it is found in the tests that the building is **"Structurally Stable"** No Objection Certificate can be issued in favour of Indian Public School, Kogilahalli, Kolar.

If any discrepancies found in the above contents the Public Works Department is having right to take back the No Objection Certificate issued.

Yours faithfully,

Sd/-
Executive Engineer,
P.W.D. Kolar Division,
Kolar



TRUE TRANSLATION DONE
FROM KANNADA TO ENGLISH

[Signature]
VENKATESHAPPA N, BA, LLB.
ADVOCATE & NOTARY PUBLIC
GOVT. OF INDIA
KOLAR - 563 101. Mob: 9480990091

[Signature]
PRINCIPAL
INDIAN PUBLIC SCHOOL
Affiliated to CBSE New Delhi
Ward No.6, Kogilahalli, NH-75
KOLAR-563101.

[Signature]
PRESIDENT
INDIAN PUBLIC SCHOOL
Ward No.6, Kogilahalli, NH-75
KOLAR-563101